





The Micro Comm driver must be programmed to send messages with the level required to activate the features listed below. Level 0 messages will always be displayed, regardless of DIP switch or resistor settings.

To block level one messages from displaying, turn on DIP switch 1.

To blank the display during a Fire Main (level three) message, turn on DIP switch 2.

To blank the display during a Fire Alternate (level two) message, remove resistor R12 (FA) from the board.

Call Tech Support at 419-636-6705 for more information.

NOTE: MUST BE USED WITH A CLASS 2 POWER SUPPLY.

CODE VERSION _____

BOARD VERSION CE2843 _

DATE DRAWN:	DRAWN BY:	REQUESTED BY:		
05/21/08	DAC	DV	C.E. ELECTRONICS, INC.	
BOARD NUMBER:	LAST DATE REVISED:	APPROVED BY:	Bryan, Ohio 43506	
2843	-		(419) 636-6705	
PRODUCT			DWG. NO.	REV:
VF312 - MICRO COMM 1.2" VF DISPLAY			VF312_01	-